

NSF Product and Service Listings

These Listings were Last Updated on **Monday, July 28, 2003** at 4:15 AM Eastern Time.
Please contact NSF International to confirm the status of any Listing, report errors, or make suggestions.

Warning: NSF is concerned about fraudulent downloading and manipulation of website text. If you have received this listing in hard copy, always confirm this certification/listing information by going directly to <http://www.nsf.org/Certified/PwsComponents/Listings.asp?Company=0V180&> for the latest most accurate information.

ANSI/NSF STANDARD 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. [Click here for a list of Abbreviations used in these Listings.](#)

SPECIALTY POLYMER
COATINGS, INC.
104 - 20529 - 62ND AVENUE
LANGLEY, BRITISH COLUMBIA V3A 8R4
CANADA
604-514-9711

Plant at: LANGLEY, BRITISH COLUMBIA, CANADA

Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
Coatings - Tank SP-7888 - 100% Solids Epoxy	[1]	CLD 23	EPOXY

[1] Certified for the following functions and sizes:

Coatings - Tank: 500 gallons and greater
Coatings - Pipe: 6" and greater
Coatings - Valve: 6" and greater
Coatings - Fittings: 6" and greater

Number of Coats: 1

Recoat/Cure Time Final Cure: 4 days

Maximum Field Use Dry Film Thickness (in mils): 21

Number of matching Manufacturers is 1

Number of matching Products is 1

Processing time was 0 seconds

NSF International

RECOGNIZES

SPECIALTY POLYMER COATINGS, INC.
LANGLEY, BRITISH COLUMBIA, CANADA

AS COMPLYING WITH NSF/ANSI 61.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



Certification Program
Accredited by the
American National
Standards Institute



Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. To verify Certification, call 800 NSF-MARK or 734 769-8010.

A handwritten signature in black ink, appearing to read "Mark L. Jost".

Mark L. Jost, Senior V.P., Water Systems
Water Distribution Systems

June 27, 2003
Certificate# OV180 - 01